## **Bay Area Air Quality Management District**

939 Ellis Street San Francisco, CA 94109 (415) 771-6000

### **Final**

## **MAJOR FACILITY REVIEW PERMIT**

# Issued To: Pacific Gas & Electric Company, Potrero Power Plant Facility #A0026

**Facility Address:** 

1201 Illinois Street San Francisco, CA 94107

**Mailing Address:** 

1201 Illinois Street San Francisco, CA 94107

**Primary Responsible Official** 

Randal S. Livingston, Manager, Steam Generation (415) 695-2607 Secondary Responsible Official Facility Contact

Michael Lyons Production Supervisor - Potrero Power Plant (415) 695-2607

Type of Facility: Primary SIC: Product:	Electric Generation 4911 Electricity	BAAQMD Permit Division Contact: Weyman Lee
ISSUED BY THE	BAY AREA AIR QUALITY	MANAGEMENT DISTRICT
Ellen Garvey, Execu	ntive Officer/Air Pollution Cont	rol Officer Date

## TABLE OF CONTENTS

I.	STANDARD CONDITIONS	1
II.	EQUIPMENT LIST	5
	A. PERMITTED SOURCE LIST	5
	B. ABATEMENT DEVICE LIST	6
III.	GENERALLY APPLICABLE REQUIREMENTS	7
IV.	SOURCE-SPECIFIC APPLICABLE REQUIREMENTS	9
V.	SCHEDULE OF COMPLIANCE	19
VI.	PERMIT CONDITIONS	19
	A. SOURCE SPECIFIC PERMIT CONDITIONS	19
VII.	APPLICABLE EMISSION LIMITS & COMPLIANCE MONITORING REQUIREMENTS	25
III.	TEST METHODS	34
IX.	TITLE IV ACID RAIN PERMIT	39
X.	GLOSSARY	42
XI.	APPENDIX A - APPLICABLE STATE IMPLEMENTATION PLAN	46

Facility Name: PG&E, Potrero Power Plant

Permit for Facility #: A0026 Expiration Date: September 14, 2003

ID: WNL

#### I. STANDARD CONDITIONS

#### A. Administrative Requirements

The permit holder shall comply with all applicable requirements in the following regulations:

BAAQMD Regulation 1 - General Provisions and Definitions

(as amended by the District Board on 11/3/93);

SIP Regulation 1 - General Provisions and Definitions

(as approved by EPA through 11/10/82);

BAAQMD Regulation 2, Rule 1 - Permits, General Requirements

(as amended by the District Board on 6/7/95);

SIP Regulation 2, Rule 1 - Permits, General Requirements

(as approved by EPA through 6/23/95);

BAAQMD Regulation 2, Rule 2 - Permits, New Source Review

(as amended by the District Board on 6/7/95);

SIP Regulation 2, Rule 2 - Permits, New Source Review and Prevention of Significant Deterioration

(as approved by EPA through 10/19/84); and

BAAQMD Regulation 2, Rule 4 - Permits, Emissions Banking

(as amended by the District Board on 6/15/94).

#### B. Conditions to Implement Regulation 2, Rule 6, Major Facility Review

- 1. This Major Facility Review Permit expires on September 14, 2003. The permit holder shall submit a complete application for renewal of this Major Facility Review Permit no later than March 14, 2003 and no earlier than September 14, 2002. **If a complete application for renewal has not been submitted in accordance with these deadlines, the facility may not operate after September 14, 2003** (Regulation 2-6-307, 404.2, & 409.6; MOP Volume II, Part 3, §4.2)
- 2. The permit holder shall comply with all conditions of this permit. The permit consists of this document and all appendices. Any non-compliance with the terms and conditions of this permit will constitute a violation of the law and will be grounds for enforcement action; permit termination, revocation and reissuance, or modification; or denial of a permit renewal application. (Regulation 2-6-307; MOP Volume II, Part 3, §4.11)
- 3. In the event any enforcement action is brought as a result of a violation of any term or condition of this permit, the fact that it would have been necessary for the permittee to halt or reduce the permitted activity in order to maintain compliance with such term or condition shall not be a defense to such enforcement action. (MOP Volume II, Part 3, §4.11)
- 4. This permit may be modified, revoked, reopened and reissued, or terminated for cause. (Regulation 2-6-307, 409.8, 415; MOP Volume II, Part 3, §4.11)
- 5. The filing of a request by the facility for a permit modification, revocation and reissuance, or termination, or of a notification of planned changes or anticipated non-compliance does not stay the applicability of any permit condition. (Regulation 2-6-409.7; MOP Volume II, Part 3, §4.11)

ID: WNL

#### I. Standard Conditions (continued)

- 6. This permit does not convey any property rights of any sort, nor any exclusive privilege. (Regulation 2-6-409.7; MOP Volume II, Part 3, §4.11)
- 7. The permit holder shall supply within 30 days any information that the District requests in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. (Regulation 1-441, Regulation 2-6-409.4 & 501; MOP Volume II, Part 3, §4.11)
- 8. Any records required to be maintained pursuant to this permit which the permittee considers to contain proprietary or trade secret information shall be prominently designated as such. Copies of any such proprietary or trade secret information which are provided to the District shall be maintained by the District in a locked confidential file, provided, however, that requests from the public for the review of any such information shall be handled in accordance with the District's procedures set forth in Section 11 of the District Administrative Code. (Regulation 2-6-419; MOP Volume II, Part 3, §4.11)
- 9. Proprietary or trade secret information provided to EPA will be subject to the requirements of 40 CFR Part 2, Subpart B Public Information, Confidentiality of Business Information. (40 CFR Part 2)
- 10. The emissions inventory submitted with the application for this Major Facility Review Permit is an estimate of actual emissions for the time period stated and is included only as one means of determining applicable requirements for emission sources. It does not establish, or constitute a basis for establishing, any new emission limitations. (MOP Volume II, Part 3, §4.11)

#### C. Requirement to Pay Fees

The permit holder shall pay annual fees in accordance with District Regulation 3, including Schedule P. (Regulation 2-6-402 & 409.13, Regulation 3; MOP Volume II, Part 3, §4.12)

#### **D.** Inspection and Entry

Access to Facility: The permit holder shall provide reasonable access to the facility and equipment which is subject to this permit to the APCO and/or to his or her designee. (Regulation 1-440, Regulation 2-6-409.3; MOP Volume II, Part 3, §4.14)

#### E. Records

Notwithstanding the specific wording in any requirement, all records for federally enforceable requirements shall be maintained for at least five years from the date of entry. (Regulation 2-6-501, Regulation 3; MOP Volume II, Part 3, §4.7)

#### F. Monitoring Reports

All required monitoring reports must be submitted to the District at least once every six months, except where an applicable requirement specifies more frequent reporting. All instances of non-compliance shall be clearly identified in these reports. The reports shall be certified by the responsible official as true, accurate, and complete. In addition, all instances of non-compliance with the permit shall be reported in writing to the District's

Facility Name: PG&E, Potrero Power Plant

Permit for Facility #: A0026 Expiration Date: September 14, 2003

ID: WNL

#### I. Standard Conditions (continued)

Compliance and Enforcement Division within 10 calendar days of the discovery of the incident. Within 30 calendar days of the discovery of any incident of non-compliance, the facility shall submit a written report including the probable cause of non-compliance and any corrective or preventative actions. The reports shall be sent to the following address:

Director of Compliance and Enforcement Bay Area Air Quality Management District 939 Ellis Street San Francisco, CA 94109 Attn: Title V Reports

(Regulation 2-6-502, Regulation 3; MOP Volume II, Part 3, §4.7)

#### **G.** Compliance Certification

Compliance certifications shall be submitted annually by the responsible official of this facility to the Bay Area Air Quality Management District and to the Environmental Protection Agency. The certification must list each applicable requirement, the compliance status, whether compliance was continuous or intermittent, the method used to determine compliance, and any other specific information required by the permit. The permit holder may satisfy this requirement through submittal of District-generated Compliance Certification forms. The certification should be directed to the District's Compliance and Enforcement Division at the address above, and a copy of the certification should be sent to the Environmental Protection Agency at the following address:

Director of the Air Division U.S. EPA, Region IX 75 Hawthorne Street San Francisco, CA 94105 Attention: Air-3

(MOP Volume II, Part 3, §4.5 and 4.15)

#### **H.** Emergency Provisions

- 1. The permit holder may seek relief from enforcement action in the event of a breakdown, as defined by Regulation 1-208 of the District's Rules and Regulations, by following the procedures contained in Regulations 1-431 and 1-432. The District will thereafter determine whether breakdown relief will be granted in accordance with Regulation 1-433. (MOP Volume II, Part 3, §4.8)
- 2 The permit holder may seek relief from enforcement action for a violation of any of the terms and conditions of this permit caused by conditions beyond the permit holder's reasonable control by applying to the District's Hearing Board for a variance pursuant to Health and Safety Code Section 42350. The Hearing Board will determine after notice

Facility Name: PG&E, Potrero Power Plant Permit for Facility #: A0026

Expiration Date: September 14, 2003

ID: WNL

#### I. Standard Conditions (continued)

and hearing whether variance relief should be granted in accordance with the procedures and standards set forth in Health and Safety Code Section 42350 et seq. Any variance granted by the Hearing Board from any term or condition of this permit which lasts longer than 90 days will be subject to EPA approval. (MOP Volume II, Part 3, §4.8)

3. Notwithstanding the foregoing, the granting by the District of breakdown relief or the issuance by the Hearing Board of a variance will not provide relief from federal enforcement unless the Major Facility Review Permit has been modified pursuant to Regulation 2, Rule 6. (MOP Volume II, Part 3, §4.8)

#### I. Severability

1. In the event that any provision of this permit is invalidated by a court or tribunal of competent jurisdiction, or by the Administrator of the EPA, all remaining portions of the permit shall remain in full force and effect. (Regulation 2-6-409.5; MOP Volume II, Part 3, §4.10)

#### J. Conditions to Implement Regulation 2, Rule 7, Acid Rain

- 1. Every year starting January 30, 2000, the permit holder shall hold one sulfur dioxide allowance on January 30 for each ton of sulfur dioxide emitted during the preceding year from January 1 through December 31. (MOP Volume II, Part 3, §4.9)
- 2. The equipment installed for the continuous monitoring of CO2 and NOx shall be maintained and operated in accordance with 40 CFR Parts 72 and 75. (Regulation 2-7, Acid Rain)
- 3. A written Quality Assurance program must be established in accordance with 40 CFR Part 75, Appendix B for NOx which includes, but is not limited to: procedures for daily calibration testing, quarterly linearity testing, record keeping and reporting implementation, and relative accuracy testing. (Regulation 2-7, Acid Rain)
- 4. The permit holder shall monitor SO2 emissions in accordance with 40 CFR Part 72 and 75. (Regulation 2-7, Acid Rain)
- 5. The permit holder shall submit quarterly Electronic Data Reports (EDR) to EPA for Boiler, S-1. These reports must be submitted within 30 days following the end of each calendar quarter and shall include all information required in § 75.64. (40 CFR Part 75)

Facility Name: PG&E, Potrero Power Plant Permit for Facility #: A0026

Expiration Date: September 14, 2003

ID: WNL

## II. EQUIPMENT LIST

## A. Permitted Source List

Each of the following sources has been issued a Permit to Operate pursuant to the requirements of BAAQMD Regulation 2-1-302.

Table II-A

S-#	Description	Make or Type	Model	Design Capacity
S-1	Boiler No. 3-1 Electric	Riley Stoker	Turbo	2150 MMBTU/hr
	Generation; Gas and Oil Fired	Corporation	Furnace	
S-10	Gas Turbine Unit No. 4 -	Turbo Power and	FT4-CIDLF	26 MW
	Engine "A" with water	Marine		
	injection; Oil Fired			
S-11	Gas Turbine Unit No. 4 -	Turbo Power and	FT4-CIDLF	26 MW
	Engine "B" with water	Marine		
	injection; Oil Fired			
S-12	Gas Turbine Unit No. 5 -	Turbo Power and	FT4-CIDLF	26 MW
	Engine "A" with water	Marine		
	injection; Oil Fired			
S-13	Gas Turbine Unit No. 5 -	Turbo Power and	FT4-CIDLF	26 MW
	Engine "B" with water	Marine		
	injection; Oil Fired			
S-14	Gas Turbine Unit No. 6 -	Turbo Power and	FT4-CIDLF	26 MW
	Engine "B" with water	Marine		
	injection; Oil Fired			
S-15	Gas Turbine Unit No. 6 -	Turbo Power and	FT4-CIDLF	26 MW
	Engine "B" with water	Marine		
	injection; Oil Fired			
S-27	Oily Water Separator	Eimco	Process	200 gal/min
			Type SB	
S-50	Paint Spraying, Facility-Wide	various spray guns		
S-51	Wipe Cleaning, Facility-Wide	custom design		
S-52	Abrasive Blasting Facility	custom design		20' x 20' x 50'
S-53	Hopper and Cleaners	Clemco	custom	
			designed	
S-54	Conveyor System	custom design		

Facility Name: PG&E, Potrero Power Plant

Permit for Facility #: A0026 Expiration Date: September 14, 2003 ID: WNL

## II. Equipment List (continued)

## **B.** Abatement Device List

**Table II-B** 

<b>A-</b> #	Description	Source(s)	Applicable	Operating	Required
		Controlled	Requirement	Parameters	Efficiency
A-52	Dust Collector Device	S-52, S-53,	Regulation	Dust Collector shall	0.002
		S-54	6-301	operate during all	gr/dscf
				times of operation	
				with a outlet grain	
				loading no greater	
				than 0.002 grain/dscf	

#### III. GENERALLY APPLICABLE REQUIREMENTS

The permit holder shall comply with all applicable requirements, including those specified in the BAAQMD and SIP Rules and Regulations and other federal requirements cited below. These requirements apply in a general manner to the facility and/or to sources exempt from the requirement to obtain a District Permit to Operate. The District has determined that these requirements would not be violated under normal, routine operations, and that no additional periodic monitoring or reporting to demonstrate compliance is warranted. In cases where a requirement, in addition to being generally applicable, is also specifically applicable to one or more sources, the requirement and the source are also included in Section IV, Source-Specific Applicable Requirements, of this permit.

The dates in parenthesis in the Title column identify the versions of the regulations being cited and are, as applicable:

- 1. BAAQMD regulation(s):
  The date(s) of adoption or most recent amendment of the regulation by the District Board
- 2. Any federal requirement, including a version of a District regulation that has been approved into the SIP:

The most recent date of EPA approval of any portion of the rule, encompassing all actions on the rule through that date

Where an applicable requirement is a SIP requirement, the full language of the SIP requirement is included in Appendix A of this permit.

#### **NOTE:**

There are differences between current BAAQMD rules and versions of the rules in the SIP. For specific information, contact the District's Planning and Research Division. All sources must comply with <u>both</u> versions of a rule until the U.S. EPA has reviewed and approved (or disapproved) the District's revision of the regulation.

Table III

		Federally
Applicable	Regulation Title or	Enforceable
Requirement	<b>Description of Requirement</b>	(Y/N)
BAAQMD Regulation 1	General Provisions and Definitions (11/3/93)	N
SIP Regulation 1	General Provisions and Definitions (11/10/82)	Y
BAAQMD Regulation 4	Air Pollution Episode Plan (3/20/91)	N
SIP Regulation 4	Air Pollution Episode Plan (8/06/90)	Y
BAAQMD Regulation 5	Open Burning (11/2/94)	N
SIP Regulation 5	Open Burning (5/3/84)	Y

Facility Name: PG&E, Potrero Power Plant Permit for Facility #: A0026

Expiration Date: September 14, 2003

ID: WNL

## III. Generally Applicable Requirements (continued)

## Table III (continued)

		Federally
Applicable	Regulation Title or	Enforceable
Requirement	Description of Requirement	(Y/N)
BAAQMD Regulation 6	Particulate Matter and Visible Emissions (12/19/90)	N
SIP Regulation 6	Particulate Matter and Visible Emissions (5/3/84)	Y
BAAQMD Regulation 7	Odorous Substances (3/17/82)	N
BAAQMD Regulation 8, Rule 1	Organic Compounds - General Provisions (6/15/94)	Y
BAAQMD Regulation 8, Rule 3	Organic Compounds - Architectural Coatings (12/20/95)	Y
BAAQMD Regulation 8, Rule 51	Organic Compounds - Adhesive and Sealant Products (12/20/95)	N
BAAQMD Regulation 9, Rule 1	Sulfur Dioxide	Y
BAAQMD Regulation 11, Rule 2	Hazardous Pollutants - Asbestos Demolition, Renovation and	Y
	Manufacturing (12/4/91)	
BAAQMD Regulation 12, Rule 4	Miscellaneous Standards of Performance - Sandblasting (7/11/90)	N
SIP Regulation 12, Rule 4	Miscellaneous Standards of Performance - Sandblasting (9/2/81)	Y
AB 2588	California Assembly Bill 2588 Toxics "Hot Spots"	N
40 CFR Part 61, Subpart M	National Emission Standards Hazardous Air Pollutants, Asbestos	Y

ID: WNL

### IV. SOURCE-SPECIFIC APPLICABLE REQUIREMENTS

The permit holder shall comply with all applicable requirements, including those specified in the BAAQMD and SIP Rules and Regulations and other federal requirements cited below. The requirements cited in the following tables apply in a specific manner to the indicated source(s).

The dates in parenthesis in the Title column identify the versions of the regulations being cited and are, as applicable:

- 1. BAAQMD regulation(s):
  - The date(s) of adoption or most recent amendment of the regulation by the District Board
- 2. Any federal requirement, including a version of a District regulation that has been approved into the SIP:

The most recent date of EPA approval of any portion of the rule, encompassing all actions on the rule through that date

The full text of each permit condition cited is included in Section VI, Permit Conditions, of this permit. Additionally, where an applicable requirement is a SIP requirement, the full language of the SIP requirement is included in Appendix A of this permit. All other text may be found in the regulations themselves.

Table IV-A S-1, Utility Boiler 3-1

Applicable Requirement	Regulation Title or Description of Requirement	Federally Enforceable (Y/N)	Future Effective Date
BAAQMD	General Provisions and Definitions (11/3/93)		
Regulation 1			
1-520	Continuous Emission Monitoring	Y	
1-520.1	Steam Generators Rated 250 MMBTU or More Per Hour	Y	
1-522	Continuous Emission Monitoring and Record Keeping Procedures	Y	
SIP	General Provisions and Definitions (11/10/82)		
Regulation 1			
1-541	Emission Excesses	$\mathbf{Y}^{1}$	
BAAQMD	Particulate Matter and Visible Emissions (12/19/90)		
Regulation 6			
6-301	Ringelmann Number 1 Limitation	N	
6-302	Opacity Limitation	Y	
6-304	Tube Cleaning	Y	
6-305	Visible Particulates	Y	
6-310	Particulate Weight Limitation	Y	

## IV. Source-Specific Applicable Requirements (continued)

## Table IV-A (continued) S-1, Utility Boiler 3-1

Applicable	Regulation Title or	Federally Enforceable	Future Effective
Requirement	Description of Requirement	(Y/N)	Date
6-310.3	Particulate Weight Limitation, Heat Transfer Operation	Y	
6-401	Appearance of Emissions	Y	
6-501	Sampling Facilities and Instruments Required	Y	
6-502	Data, Records and Reporting	Y	
SIP	Particulate Matter and Visible Emissions		
Regulation 6			
6-301	Ringelmann Number 1 Limitation (9/5/79)	$\mathbf{Y}^{1}$	
BAAQMD	Inorganic Gaseous Pollutants, Sulfur Dioxide (3/15/95)		
Regulation			
9, Rule 1			
9-1-301	Limitations on Ground Level Concentrations	N	
9-1-302	General Emission Limitation	Y	
9-1-304	Fuel Burning (Liquid and Solid Fuels)	Y	
SIP	Inorganic Gaseous Pollutants, Sulfur Dioxide (5/3/84)		
Regulation			
9, Rule 1			
9-1-301	Limitations on Ground Level Concentrations	$Y^1$	
BAAQMD	Inorganic Gaseous Pollutants, Nitrogen Oxides From Heat		
Regulation	Transfer Operations (3/17/82)		
9, Rule 3			
9-3-301	Existing Heat Transfer Operation Limits	N	
9-3-302	Different Fuels in Existing Heat Transfer Operations	N	
BAAQMD	Inorganic Gaseous Pollutants, Nitrogen Oxides and Carbon		
Regulation	Monoxide From Utility Electric Power Generating Boilers		
9, Rule 11	(11/15/95)		
9-11-111	Exemption, Startup or Shutdown	Y	
9-11-112	Exemption, Oil Testing	Y	
9-11-302	Interim Compliance NOx Emission Limits for Boilers with a Rated Heat Input Capacity Greater Than or Equal to 1.75 billion BTU/hour	Y	
9-11-302.1	NOX limits, limitation on non-gaseous fuel firing	Y	

ID: WNL

## IV. Source-Specific Applicable Requirements (continued)

## Table IV-A (continued) S-1, Utility Boiler 3-1

Applicable Requirement	Regulation Title or  Description of Requirement	Federally Enforceable (Y/N)	Future Effective Date
9-11-308	System-wide NOx Emission Rate Limit	Y	
9-11-309	Advanced Technology Alternative Emission Control Plan	N	
9-11-309.1	System-wide NOx Emission Rate Limits: 0.160 lb/MMBTU	N	
9-11-309.1	System-wide NOx Emission Rate Limits: 0.115 lb/MMBTU	N	1/1/99
9-11-309.1	System-wide NOx Emission Rate Limits: 0.105 lb/MMBTU	N	1/1/00
9-11-309.1	System-wide NOx Emission Rate Limits: 0.057 lb/MMBTU	N	1/1/02
9-11-309.1	System-wide NOx Emission Rate Limits: 0.037 lb/MMBTU	N	1/1/04
9-11-309.1	System-wide NOx Emission Rate Limits: 0.018 lb/MMBTU	N	1/1/06
9-11-309.2	Boilers in Startup or Shutdown; Boilers Taken Out of Service; Boilers on Force Majeure Natural Gas Curtailment; and Oil Testing	N	
9-11-310	CO Emission Limits for Boilers with a Rated Heat Input Capacity Greater Than or Equal to 250 million BTU/hour	Y	
9-11-311	Ammonia Emission Limit for Boilers with a Rated Heat Input Capacity Greater Than or Equal to 250 million BTU/hour	Y	Upon installment of an applicable emission control device
9-11-401	Compliance Schedule - Emissions Limits	Y	
9-11-402	Initial and Annual Demonstration of Compliance	Y	
9-11-501	Fuels Monitoring	Y	
9-11-502	Modified Maximum Heat Input Capacity	Y	Upon physical modification affecting max. heat input
9-11-503	Emissions Monitoring	Y	
9-11-504	Records	Y	
9-11-505	Reporting Requirements	Y	
BAAQMD Regulation 11, Rule 1	Hazardous Pollutants, Lead (3/17/82)		
11-1-301	Daily Limitation	Y	
11-1-302	Ground level Concentration Limit Without Background	Y	

Facility Name: PG&E, Potrero Power Plant Permit for Facility #: A0026

Expiration Date: September 14, 2003

ID: WNL

### IV. Source-Specific Applicable Requirements (continued)

## Table IV-A (continued) S-1, Utility Boiler 3-1

Applicable	Regulation Title or	Federally Enforceable	Future Effective
Requirement	Description of Requirement	(Y/N)	Date
BAAQMD Manual of	Continuous Emission Monitoring Policy and Procedures (1/20/82)	Y	
Procedures,			
Volume V			
40 CFR	Title IV – Acid Rain Program	Y	
Part 72			
40 CFR	Code of Federal Regulations, Continuous Emissions Monitoring	Y	
Part 75			

There are differences between the current BAAQMD rule and the version of the rule in the SIP. For specific information, contact the District's Rule Development Section of the Enforcement Division. All sources must comply with <u>both</u> versions of the rule until US EPA has reviewed and approved (or disapproved) the District's revision of the regulation.

#### Table IV-B

S-10 Gas Turbine Unit No. 4-Engine "A" S-11 Gas Turbine Unit No. 4-Engine "B" S-12 Gas Turbine Unit No. 5-Engine "A" S-13 Gas Turbine Unit No. 5-Engine "B" S-14 Gas Turbine Unit No. 6-Engine "A" S-15 Gas Turbine Unit No. 6-Engine "B"

		Federally	Future
Applicable	Regulation Title or	Enforceable	Effective
Requirement	Description of Requirement	(Y/N)	Date
BAAQMD	Particulate Matter and Visible Emissions (12/19/90)		
Regulation 6			
6-301	Ringelmann Number 1 Limitation	N	
6-305	Visible Particulates	Y	
6-310	Particulate Weight Limitation	Y	
6-401	Appearance of Emissions	Y	

## IV. Source-Specific Applicable Requirements (continued)

#### **Table IV-B (continued)**

S-10 Gas Turbine Unit No. 4-Engine "A"

S-11 Gas Turbine Unit No. 4-Engine "B"

S-12 Gas Turbine Unit No. 5-Engine "A"

S-13 Gas Turbine Unit No. 5-Engine "B"

S-14 Gas Turbine Unit No. 6-Engine "A"

S-15 Gas Turbine Unit No. 6-Engine "B"

		Federally	Future
Applicable	Regulation Title or	Enforceable	Effective
Requirement	Description of Requirement	(Y/N)	Date
SIP	Particulate Matter and Visible Emissions		
Regulation 6			
6-301	Ringelmann Number 1 Limitation (9/5/79)	$\mathbf{Y}^{1}$	
BAAQMD	Inorganic Gaseous Pollutants, Sulfur Dioxide (3/15/95)		
Regulation			
9, Rule 1			
9-1-301	Limitations on Ground Level Concentrations	N	
9-1-302	General Emission Limitation	Y	
9-1-304	Fuel Burning (Liquid and Solid Fuels)	Y	
SIP	Inorganic Gaseous Pollutants, Sulfur Dioxide (5/3/84)		
Regulation			
9, Rule 1			
9-1-301	Limitations on Ground Level Concentrations	$\mathbf{Y}^{1}$	
BAAQMD	Inorganic Gaseous Pollutants, Nitrogen Oxides From		
Regulation	Stationary Gas Turbines (9/21/94)		
9, Rule 9			
9-9-114	Exemption, Start-up and Shutdown Periods	Y	
9-9-302	Emission Limits, Low Usage	Y	
9-9-502	Records, Low Usage	Y	
BAAQMD			
Cond #15816			
Part 1	Visible emissions monitoring	Y	
Part 2	Recordkeeping for visible emissions monitoring	Y	
Part 3	Water injection	Y	
Part 4	Fuel specification	Y	_

Facility Name: PG&E, Potrero Power Plant

Permit for Facility #: A0026 Expiration Date: September 14, 2003

Expiration Date: September 14, 2003 ID: WNL

## IV. Source-Specific Applicable Requirements (continued)

Part 5	Hours of operation limitation	Y	
Part 6	Recordkeeping	Y	

There are differences between the current BAAQMD rule and the version of the rule in the SIP. For specific information, contact the District's Rule Development Section of the Enforcement Division. All sources must comply with <u>both</u> versions of the rule until US EPA has reviewed and approved (or disapproved) the District's revision of the regulation.

ID: WNL

## IV. Source-Specific Applicable Requirements (continued)

Table IV-C S-27, Oily-Water Separator

Applicable Requirement BAAQMD Regulation	Regulation Title or  Description of Requirement  Organic Compounds, Wastewater (Oil-Water) Separator (6/15/94)	Federally Enforceable (Y/N)	Future Effective Date
8, Rule 8	(0.15/74)		
8-8-112	Exemption, Wastewater Critical Organic Compound Concentration And/Or Temperature	Y	
8-8-113	Exemption, Secondary Wastewater Treatment Processes and Stormwater Sewer Systems	Y	
8-8-303	Gauging and Sampling Devices	Y	
8-8-305	Oil-Water Separator And/Or Air Flotation Unit Slop Oil Vessels	Y	
8-8-501	API Separator or Air Flotation Bypassed Wastewater Records	Y	
8-8-502	Wastewater Critical Organic Compound Concentration And/Or Temperature Records	Y	
8-8-503	Inspection and Repair Records	Y	

Table IV-D S-50, Paint Spraying, Facility-Wide

Applicable Requirement BAAQMD Regulation	Regulation Title or Description of Requirement Organic Compounds, Surface Coating of Miscellaneous Metal Parts and Products (12/20/95)	Federally Enforceable (Y/N)	Future Effective Date
8, Rule 19			
8-19-302	Limits	Y	
8-19-307	Prohibition of Specification	Y	
8-19-308	Compliance Statement Requirement	Y	
8-19-313	Spray Application Equipment Limitations	Y	
8-19-320	Solvent Evaporative Loss Minimization	Y	
8-19-501	Records	Y	

## IV. Source-Specific Applicable Requirements (continued)

## Table IV-D (continued) S-50, Paint Spraying, Facility-Wide

Applicable	Regulation Title or	Federally Enforceable	Future Effective
Requirement	Description of Requirement	(Y/N)	Date
BAAQMD	Organic Compounds - Coating of Flat Wood Paneling and		
Regulation 8,	Wood Flat Stock (12/20/95)		
Rule 23			
8-23-301	VOC Limits	Y	
8-23-401	Coating List Requirement	Y	
8-23-501	Records	Y	
BAAQMD Regulation 8, Rule 31	Organic Compounds - Surface Coating of Plastic Parts and Products (12/20/95)		
8-31-302	VOC Limit	Y	
8-31-306	Flexible Coatings	Y	
8-31-307	Prohibition of Specification	Y	
8-31-308	Compliance Statement Requirements	N	
8-31-309	VOC Limits	Y	
8-31-310	Spray Application Equipment Requirements	Y	
8-31-320	Solvent Evaporative Minimization Requirements	Y	
8-31-401	Coating Petition	Y	
8-31-501	Records	Y	
BAAQMD Condition #6062	Permit Conditions		
Condition 1	Total Paint Usage Limit (basis: cumulative increase)	Y	
Condition 2	Total Cleanup Solvent Limit (basis: cumulative increase)	Y	
Condition 3	VOC Content Limit (basis: BAAQMD Regulation 8-19-302.2)	Y	
Condition 4	Record Keeping Provisions for Adding Components To Coatings (basis: BAAQMD Regulation 8-19-501.2)	Y	
Condition 5	Coating and Cleanup Solvent Log (basis: BAAQMD Regulation 8-19-501)	Y	

## IV. Source-Specific Applicable Requirements (continued)

Table IV-E S-51, Wipe Cleaning, Facility-Wide

Applicable Requirement	Regulation Title or Description of Requirement	Federally Enforceable (Y/N)	Future Effective Date
BAAQMD	Organic Compounds, Solvent Cleaning Operations (6/15/94)		
Regulation			
8, Rule 16			
BAAQMD	Exemption, Wipe Cleaning	Y	
8-16-111			
BAAQMD	Trichloroethylene Limitation	Y	
8-16-304			
BAAQMD	Solvent Records	Y	
8-16-501			
BAAQMD	Permit Conditions		
Condition			
#6062			
Condition 1	1, 1, 1-trichloroethane Usage Limit (basis: cumulative increase)	N	
Condition 2	Storing Cloth or Paper Impregnated With 1, 1, 1-trichloroethane	Y	
	(basis: BAAQMD Regulation 8-1-320)		
Condition 3	1, 1, 1-trichloroethane Records, Five Year Maintenance	Y	
	(basis: BAAQMD Regulation 8-16-501)		
Condition 3a	1, 1, 1-trichloroethane Records, Daily Usage	N	
	(basis: cumulative increase)		
Condition 3b	1, 1, 1-trichloroethane Records, VOC Content	Y	
	(basis: BAAQMD Regulation 8-4-501.1)		

ID: WNL

## IV. Source-Specific Applicable Requirements (continued)

### Table IV-F S-52, Abrasive Blasting Facility S-53, Hopper & Cleaners S-54, Conveyor System

Applicable Requirement	Regulation Title or Description of Requirement	Federally Enforceable (Y/N)	Future Effective Date
CA Title 17	State Provisions for Sandblasting	N	
BAAQMD	Particulate Matter and Visible Emissions (12/19/90)		
Regulation 6			
6-301	Ringelmann Number 1 Limitation	Y	
6-305	Visible Particles	Y	
6-310	Particulate Weight Limitation	Y	
6-401	Appearance of Emissions	Y	
SIP	Particulate Matter and Visible Emissions (6/16/83)		
Regulation 6			
6-301	Ringelmann Number 1 Limitation (9/5/79)	$\mathbf{Y}^{1}$	
BAAQMD	Permit Conditions		
Condition			
#7512			
Condition 1	Ringelmann Limit (basis: cumulative increase)	Y	
Condition 2	Aluminum Oxide Monthly Usage Limit (basis: cumulative increase)	Y	
Condition 3	Abrasive Blasting Material Daily Usage Limit	Y	
	(basis: cumulative increase)		
Condition 4	Dust Collector System Requirement (basis: cumulative increase)	Y	
Condition 5	Particulate Loading Limit (basis: cumulative increase)	Y	
Condition 6	Records (basis: cumulative increase)	Y	

There are differences between the current BAAQMD rule and the version of the rule in the SIP. For specific information, contact the District's Rule Development Section of the Enforcement Division. All sources must comply with <u>both</u> versions of the rule until US EPA has reviewed and approved (or disapproved) the District's revision of the regulation.

Facility Name: PG&E, Potrero Power Plant Permit for Facility #: A0026

Expiration Date: September 14, 2003

ID: WNL

#### V. SCHEDULE OF COMPLIANCE

The permit holder shall continue to comply with all applicable requirements cited in this permit. The permit holder shall also comply with applicable requirements that become effective during the term of this permit.

#### VI. PERMIT CONDITIONS

Any condition that is preceded by an asterisk is not federally enforceable.

#### A. Source Specific Permit Conditions

#### **Condition # 6062**

For S-50 Paint Spraying, Facility-Wide

- 1. Total paint usage shall not exceed 1095 gallons in any consecutive 12 month period. (basis: cumulative increase)
- 2. Total cleanup solvent usage shall not exceed 100 gallons in any consecutive 12 month period. (basis: cumulative increase)
- 3. The maximum VOC content of any coating, as applied, shall not be greater than 2.8 lb/gal. (basis: BAAQMD Regulation 8-19-302.2)
- 4. Catalysts, hardeners, reducers, thinning solvents, and other components shall only be added to coating in proportions not exceeding the manufacturer's recommendations for the coatings complying with Regulation 8, Rule 19 Surface Coating of Miscellaneous Metal Parts and Products, Rule 23 Coating of Flatwood Paneling, and Rule 31 Surface Coating of Plastic Parts and Products. (basis: Regulation 8-19-501.2)

Expiration Date: September 14, 2003

ID: WNL

#### VI. Permit Conditions (continued)

#### A. Source Specific Permit Conditions (continued)

#### **Condition # 6062 (continued)**

For S-50 Paint Spraying, Facility-Wide

- 5. Usage of all coatings and cleanup solvents shall be recorded in the District-approved log and retained for at least five years from the date of entry. This log will contain the following information:
  - a) Coating, catalysts, and reducers used (product identification numbers),
  - b) mix ratio of components used,
  - c) VOC content of coating as applied,
  - d) quantity of coating applied,
  - e) type and amount of all surface preparation and clean up solvents used at this source.

This log shall be kept on site and made available to the District staff on request. (basis: BAAQMD Regulation 8-19-501)

#### For S-51 Wipe Cleaning, Facility-Wide

- 1.\* Total amount of 1,1,1-trichloroethane used at this source shall not exceed 55 gallons in any consecutive 12 month period or previous 12 (twelve) months. (basis: cumulative increase)
- 2. Cloth or paper impregnated with 1,1,1-trichloroethane shall be stored or disposed of in closed containers. (basis: BAAQMD Regulation 8-1-320)
- 3. Fresh or spent 1,1,1-trichloroethane shall be recorded in a District approved log and retained for at least five years from the date of entry. This log will contain the following information: (basis: BAAQMD Regulation 8-16-501)
  - a)\* Daily amount of 1,1,1-trichloroethane used, (basis: cumulative increase)
  - b) Volatile organic compound (VOC) content of 1,1,1-trichloroethane. (basis: BAAQMD Regulation 8-4-501.1)

This log shall be kept on site and made available to District staff on request. (basis: BAAQMD Regulation 8-4-501 & 8-16-501)

Facility Name: PG&E, Potrero Power Plant Permit for Facility #: A0026

Expiration Date: September 14, 2003 ID: WNL

#### VI. Permit Conditions (continued)

#### A. Source Specific Permit Conditions (continued)

#### **Condition #7512**

For S-52, Abrasive Blasting Facility S-53, Hopper & Cleaners S-54, Conveyor System A-52, Dust Collector System

- 1. Visible particulate emissions from this blasting facility, including S-52, S-53, S-54, and A-52, shall not exceed Ringelmann 1.0 or result in fallout on adjacent property in such quantities as such to cause public nuisance per Regulation 1-301. (basis: cumulative increase)
- 2. The total amount of abrasive used at Abrasive Blasting Facility (S-52, S-53, and S-54) shall not exceed 1,700 tons of aluminum oxide during any consecutive 12 month period. (basis: cumulative increase)
- 3. The total amount of abrasive used at S-52, S-53, and S-54 shall not exceed 13.1 tons during any day. (basis: cumulative increase)
- 4. Emissions from Abrasive Blasting Facility S-52, S-53, and S-54 shall be abated by the properly maintained Dust Collector System, A-52, at all times that S-52, S-53, and or S-54 are in operation. A District-approved dust collector failure warning device must be in operation at all such times. (basis: cumulative increase)
- 5. The particulate loading at the exit of A-52, dust collector, shall not exceed 0.002 grain/dscf. (basis: cumulative increase)
- 6.\* Within 60 days of startup of S-52, S-53, S-54, and A-52, the owner or operator shall perform a source test, approved by the District's Source Test Manager, on S-52, S-53, S-54, and A-52 to determine compliance with Condition 5 above. The source test shall be conducted with S-52, S-53, and S-54 operating at the full rated capacity of 1.31 ton/hour.(basis: performance testing)

Facility Name: PG&E, Potrero Power Plant

Permit for Facility #: A0026 Expiration Date: September 14, 2003

ID: WNL

#### VI. Permit Conditions (continued)

#### A. Source Specific Permit Conditions (continued)

#### **Condition #7512 (continued)**

For S-52, Abrasive Blasting Facility S-53, Hopper & Cleaners S-54, Conveyor System A-52, Dust Collector System

- 67. In order to demonstrate compliance with the above conditions, the owner/operator of S-52, S-53, S-54, and A-52 shall maintain the following records in a District-approved log. These records shall be kept on site and made available for District inspection for a period of five years from the date that the record was made.
  - a) Daily throughput of abrasive blasting material, summarized on a monthly basis.
  - b) Daily hours of operation, summarized on a monthly basis. (basis: cumulative increase)

#### **Condition #15816**

For S-10, S-11, S-12, S-13, S-14, and S-15 [Gas Turbines]

- 1. For each emission point at S-10, S-11, S-12, S-13, S-14, and S-15 Gas Turbine, the owner/operator shall follow either a) or b), as appropriate, upon receipt of public complaint, upon obvious emissions, but no less than once each day when operated. The daily inspection shall be conducted while the equipment is operating and during daylight hours. [basis: District Regulations 6-301, 302, 2-6-501]
  - a) If three (3) or fewer exceedances have been recorded at any emission point within the last six (6) months, conduct an inspection for visible emissions from that emission point. If any visible emissions, excluding condensed water vapor, are detected during an inspection and the emissions are observed continuously or intermittently for three (3) minutes, the owner/operator shall either:
    - (i) Take corrective actions that eliminate the visible emissions and report the visible emission as a potential exceedance. If all visible emissions are not eliminated through corrective actions as soon as possible but no later than within 24 hours, the procedure in paragraph (ii) below shall be followed; or

#### **Condition #15816 (continued)**

Facility Name: PG&E, Potrero Power Plant

Permit for Facility #: A0026 Expiration Date: September 14, 2003

ID: WNL

#### VI. Permit Conditions (continued)

#### A. Source Specific Permit Conditions (continued)

For S-10. S-11, S-12, S-13, S-14, and S-15 [Gas Turbines]

- (ii) Have a CARB-certified smoke reader determine compliance with the opacity standard, using EPA Method 9 or the procedures outlined in the CARB manual, "Visible Emissions Evaluation" for six (6) minutes within three (3) days and record the results of the reading. The certified smoke-reader shall continue to conduct the Method 9 or CARB Visible Emission Evaluation on a daily basis until the daily reading shows compliance with the applicable limit or until the equipment is shut down.
- b. If more than three (3) exceedances have been recorded at any emission point within the last six (6) months, a CARB-certified smoke reader shall conduct either an EPA Method 9 or the procedures outlined in the CARB manual, "Visible Emissions Evaluation" for six (6) minutes at that emission point.
- 2. For each turbine covered by permit condition no. 1 above, the owner/operator shall record and maintain the following records: [basis: District Regulation 2-6-501]
  - a) each day monitoring under 1(a) or 1(b) is required:
    - i) date and time of inspection, and name of inspector
    - ii) stack or emission point identification
  - b) each day for each emission point where corrective action is required under 1(a)(I):
    - i) nature of visible emissions
    - ii) description of corrective actions taken to abate visible emissions
    - iii) date and time visible emission was abated
  - c) each day for each emission point where EPA Method 9 or CARB visible emission evaluation is required under (1)(b) or (1)(a)(ii):
    - i) visible emission observation record by a certified smoke reader
    - ii) name of person performing the inspection, measurement, or monitoring

#### **Condition #15816 (continued)**

For S-10. S-11, S-12, S-13, S-14, and S-15 [Gas Turbines]

Facility Name: PG&E, Potrero Power Plant
Permit for Facility #: A0026

Expiration Date: September 14, 2003 ID: WNL

#### VI. Permit Conditions (continued)

#### A. Source Specific Permit Conditions (continued)

The records shall be retained for five (5) years and shall be made available to District personnel upon request.

- 3. S-10, S-11, S-12, S-13, S-14, and S-15 shall be abated at all times of operation by a properly operated and properly maintained water injection system. The weight ratio of water to fuel shall not be less than 0.55 during normal operation. [basis: District Regulation 9-9-302]
- 4. S-10, S-11, S-12, S-13, S-14, and S-15 Turbines shall be fired exclusively on No. 2 distillate oil or lighter fuel oil with a sulfur content less than 0.5% sulfur by weight. [basis: District Regulation 9-304]
- 5. S-10, S-11, S-12, S-13, S-14, and S-15 Turbines shall be operated less than 877 hours each in any calendar year unless the emissions requirements of District Regulation 9-9-301 are met. [basis: District Regulations 6-310; 9-9-301, 302]
- 6. In order to demonstrate compliance with the above permit conditions numbers 3, 4, and 5, the following records shall be maintained in a District approved log. These records shall be kept on site and made available for District inspection for a period of at least five (5) years from the date on which a record is made. [basis: District Regulation 2-6-501]
  - a. The water to fuel weight ratio for each turbine on a daily basis when operating.
  - b. The type of fuel and sulfur content of the fuel fired.
  - c. The total number of hours of operation, totaled on a monthly basis.

ID: WNL

## VII. APPLICABLE EMISSION LIMITS & COMPLIANCE MONITORING REQUIREMENTS

This section has been included only to summarize the applicable emission limits contained in Section IV, Source-Specific Applicable Requirements, of this permit. The following tables show the relationship between each emission limit and the associated compliance monitoring provisions, if any. The monitoring frequency indicates whether periodic (P) or continuous (C) monitoring is required. For periodic monitoring, the frequency of the monitoring has also been shown, either annual (A), quarterly (Q), monthly (M), daily (D), or on an event basis (E). No monitoring (N) has been required if the current applicable rule or regulation does not require monitoring, and the operation is unlikely to deviate from the applicable emission limit based upon the nature of the operation.

Table VII-A S-1, Utility Boiler 3-1

	Emission Limit	FE	Future Effective		Monitoring Requirement	Monitoring Frequency	Monitoring
Pollutant	Citation	Y/N	Date	Emission Limit	Citation	(P/C/N)	Type
TSP	BAAQMD 6-301	N		Ringelmann No. 1		С	СОМ
	BAAQMD 6-302	Y		< 20% opacity during any 3 min/hr	BAAQMD 1-520.1	С	COM
	BAAQMD 6-304	Y		Ringelmann No. 2 during tube cleaning	2 0 2 8 1 2	С	COM
	BAAQMD 6-310.3	Y		0.15 grains/dscf @ 6% O <sub>2</sub>		N	
	SIP 6-301	Y		Ringelmann No. 1		С	COM
	40 CFR 75	Y		None	40 CFR 75	С	COM
$SO_2$	9-1-301	N		GLC <sup>1</sup> of 0.5 ppm for 3 minutes or 0.25 ppm for 60 minutes or 0.05 ppm for 24 hours		N	
	BAAQMD 9-1-302	Y		300 ppmvd		N	
	BAAQMD 9-1-304	Y		Sulfur content of non- gaseous fuel <0.5% by weight		N	

## VII. Applicable Emission Limits & Compliance Monitoring Requirements (continued)

### Table VII-A (continued) S-1, Utility Boiler 3-1

	Emission		Future		Monitoring	Monitoring	
	Limit	FE	Effective		Requirement	Frequency	Monitoring
Pollutant	Citation	Y/N	Date	<b>Emission Limit</b>	Citation	(P/C/N)	Type
SO2	SIP	Y		Federal std: GLC <sup>1</sup> of		N	
	9-1-301			140 ppb, 24-hr			
				average, once/yr and			
				30 ppb, annual			
				average			
				State std: GLC <sup>1</sup> of 40			
				ppb, 24-hr average,			
				and 250 ppb, 1 hr			
				average			
	40 CFR 75	Y		None	40 CFR 75	P/D (fuel oil	fuel analysis
						only)	
$NO_X$	BAAQMD	N		175 ppmv		С	CEMS
	9-3-301			@ 3% O <sub>2</sub> (dry basis)			
				for natural gas firing			
				or 300 ppmv			
				@ 3% O <sub>2</sub> (dry basis)			
				for oil firing			
				based on a clock hour			
				average			
	BAAQMD	Y		heat input weighted		С	CEMS
	9-3-302			average of emissions			
				when natural gas and			
				oil fired			
				simultaneously			
	BAAQMD	Y		175 ppmv	BAAQMD	С	CEMS
	9-11-302.1.1			@ 3% O <sub>2</sub> (dry basis)	9-11-501, 503		
				for natural gas firing			
				based on a clock hour			
				average			

## VII. Applicable Emission Limits & Compliance Monitoring Requirements (continued)

### Table VII-A (continued) S-1, Utility Boiler 3-1

	Emission		Future		Monitoring	Monitoring	
	Limit	FE	Effective		Requirement	Frequency	Monitoring
Pollutant	Citation	Y/N	Date	<b>Emission Limit</b>	Citation	(P/C/N)	Type
$NO_X$	BAAQMD	Y		300 ppmv	BAAQMD	С	CEMS
	9-11-302.1.2			@ 3% O <sub>2</sub> (dry basis)	9-11-501, 503		
				for oil firing			
				based on a clock hour			
				average			
	BAAQMD	Y		heat input weighted	BAAQMD	С	CEMS
	9-11-302.1.3			average of emissions	9-11-501, 503		
				when natural gas and			
				oil fired			
				simultaneously			
	BAAQMD	Y		0.28 lbs/MMBTU	BAAQMD	С	CEMS
	9-11-308			system-wide average	9-11-501, 503		
				over previous 30 days			
	BAAQMD	N		0.160 lbs/MMBTU	BAAQMD	С	CEMS
	9-11-309.1			system-wide average	9-11-501, 503		
				on a clock hour basis			
	BAAQMD	N	1/1/99	0.115 lbs/MMBTU	BAAQMD	С	CEMS
	9-11-309.1			system-wide average	9-11-501, 503		
				on a clock hour basis			
	BAAQMD	N	1/1/00	0.105 lbs/MMBTU	BAAQMD	С	CEMS
	9-11-309.1			system-wide average	9-11-501, 503		
				on a clock hour basis			
	BAAQMD	N	1/1/02	0.057 lbs/MMBTU	BAAQMD	С	CEMS
	9-11-309.1			system-wide average	9-11-501, 503		
				on a clock hour basis			
	BAAQMD	N	1/1/04	0.037 lbs/MMBTU	BAAQMD	C	CEMS
	9-11-309.1			system-wide average	9-11-501, 503		
				on a clock hour basis			
	BAAQMD	N	1/1/05	0.018 lbs/MMBTU	BAAQMD	С	CEMS
	9-11-309.1			system-wide average	9-11-501, 503		
				on a clock hour basis			
	40 CFR 75	Y		None	40 CFR 75	С	CEMS

## VII. Applicable Emission Limits & Compliance Monitoring Requirements (continued)

### Table VII-A (continued) S-1, Utility Boiler 3-1

	Emission Limit	FE	Future Effective		Monitoring Requirement	Monitoring Frequency	Monitoring
Pollutant	Citation	Y/N	Date	<b>Emission Limit</b>	Citation	(P/C/N)	Туре
СО	BAAQMD	Y		400 ppmv	BAAQMD	С	CEMS
	9-11-310.1			@ 3% O <sub>2</sub> (dry basis)	9-11-501, 503		
				during steady state			
				compliance tests			
	BAAQMD	Y		1000 ppmv	BAAQMD	С	CEMS
	9-11-310.2			@ 3% O <sub>2</sub> (dry basis)	9-11-501, 503		
				during normal			
				operation based on a			
				clock hour average			
Ammonia	BAAQMD	Y		10 ppmv	BAAQMD	P/Q	Quarterly
	9-11-311			@ 3% O <sub>2</sub> (dry basis)	9-11-402		tests
				based on rolling 60			
				minute average upon			
				installation of an			
				applicable control			
				device			
Lead	BAAQMD	Y		6.75 kg/day		N	N/A
	11-1-301						
	BAAQMD	Y		$1.0  \mu g/m^3$		N	N/A
	11-1-302			averaged over 24 hours			
$CO_2$	40 CFR 75	Y		None	40 CFR 75	С	CEMS

## VII. Applicable Emission Limits & Compliance Monitoring Requirements (continued)

#### **Table VII-B**

S-10, Gas Turbine Unit No. 4-Engine "A" S-11, Gas Turbine Unit No. 4-Engine "B" S-12, Gas Turbine Unit No. 5-Engine "A" S-13, Gas Turbine Unit No. 5-Engine "B" S-14, Gas Turbine Unit No. 6-Engine "A"

S-15, Gas Turbine Unit No. 6-Engine "B"

	Emission Limit	FE	Future Effective		Monitoring Requirement	Monitoring Frequency	Monitoring
Pollutant	Citation	Y/N	Date	Emission Limit	Citation	(P/C/N)	Type
TSP	BAAQMD 6-301 BAAQMD	N		Ringelmann No. 1  0.15 grains/dscf	BAAQMD permit condition 15816 Parts 1, 2	P/D Daily when in use	Visual Inspection and record keeping
	6-310.3	11		@ 6% O <sub>2</sub>		11	
	SIP 6-301	Y		Ringelmann No. 1	BAAQMD permit condition 15816 parts 1, 2	P/D Daily when in use	Visual Inspection and record keeping
SO <sub>2</sub>	BAAQMD 9-1-301	N		GLC <sup>1</sup> of 0.5 ppm for 3 minutes or 0.25 ppm for 60 minutes or 0.05 ppm for 24 hours		N	
	9-1-302	Y		300 ppmvd		N	
	BAAQMD 9-1-304	Y		Sulfur content of non- gaseous fuel <0.5% by weight	BAAQMD cond #15816, part 6	P/E	fuel analysis
	SIP 9-1-301	N		Federal std: GLC <sup>1</sup> of 140 ppb, 24-hr average, once/yr and 30 ppb, annual average State std: GLC <sup>1</sup> of 40 ppb, 24-hr average, and 250 ppb, 1 hr average		N	

## VII. Applicable Emission Limits & Compliance Monitoring Requirements (continued)

#### **Table VII-B (continued)**

S-10, Gas Turbine Unit No. 4-Engine "A"

S-11, Gas Turbine Unit No. 4-Engine "B"

S-12, Gas Turbine Unit No. 5-Engine "A"

S-13, Gas Turbine Unit No. 5-Engine "B"

S-14, Gas Turbine Unit No. 6-Engine "A"

S-15, Gas Turbine Unit No. 6-Engine "B"

	Emission		Future		Monitoring	Monitoring	
	Limit	FE	Effective		Requirement	Frequency	Monitoring
Pollutant	Citation	Y/N	Date	<b>Emission Limit</b>	Citation	(P/C/N)	Туре
$NO_X$	BAAQMD	Y		65 ppmv	BAAQMD	P/D	Record-
	9-9-302			@ 15% O <sub>2</sub> (dry basis)	9-9-502	Daily when	keeping
	&			based on a clock hour	&	in use	
	BAAQMD			average	BAAQMD		
	permit			&	permit		
	condition			operation less than	condition		
	15816			877 hours per	15816		
	part 5			calendar year	part 6		
Water	Record-	Y		Weight ratio of water	BAAQMD	P/D	Record-
injection	keeping			to fuel not less than	permit	Daily when	keeping
rate				0.55	condition	in use	
					15816		
					part 6		
Fuel oil	BAAQMD	Y		Use of No. 2 or lighter	BAAQMD	P/D	Record-
restriction	permit			oil.	permit	Daily when	keeping
	condition				condition	in use	
	15816				15816		
	part 4				part 6		

## VII. Applicable Emission Limits & Compliance Monitoring Requirements (continued)

### Table VII-C S-27, Oily-Water Separator

	Emission		Future		Monitoring	Monitoring	
	Limit	FE	Effective		Requirement	Frequency	Monitoring
Pollutant	Citation	Y/N	Date	<b>Emission Limit</b>	Citation	(P/C/N)	Type
VOC	BAAQMD	Y	current	1.0 ppm critical	N/A	P/	Sampling
	8-8-112			organic compounds @		Semi-annual	
				68 °F			

Table VII-D S-50, Paint Spraying, Facility-Wide

	Emission Limit	FE	Future Effective		Monitoring Requirement	Monitoring Frequency	Monitoring
Pollutant	Citation	Y/N	Date	<b>Emission Limit</b>	Citation	(P/C/N)	Type
VOC	BAAQMD	Y		content of air dried	Regulation	P/E	Records
	Regulation			coating < 2.8 lb/gal	8-19-501		
	8-19-302						
	And						
	BAAQMD						
	Permit						
	Condition						
	6062 part 3						
	BAAQMD	Y		content of coatings <	Regulation	P/E	Records
	Regulation			specified VOC	8-19-501		
	8-19-312			content			
	BAAQMD	Y		content of coatings <	Regulation	P/E	Records
	Regulation			2.1 lb/gal	8-23-501		
	8-23-301						
	BAAQMD	Y		content of coatings <	Regulation	P/E	Records
	Regulation			specified VOC	8-31-501		
	8-31-302			content			

ID: WNL

## VII. Applicable Emission Limits & Compliance Monitoring Requirements (continued)

### Table VII-D (continued) S-50, Paint Spraying, Facility-Wide

Pollutant	Emission Limit Citation	FE Y/N	Future Effective Date	Emission Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring
			Date			, ,	Туре
VOC	BAAQMD	Y		content of coatings <	Regulation	P/E	Records
	Regulation			specified VOC	8-31-501		
	8-31-306			content			
	BAAQMD	Y		content of coatings <	Regulation	P/E	Records
	Regulation			specified VOC	8-31-501		
	8-31-309			content			
Paint Usage	BAAQMD	Y		1095 gal/yr	BAAQMD	P/E	Records
	Permit			in any 12 consecutive	Permit		
	Condition			months	Condition		
	6062 part 1				6062 part 5		
Cleanup	BAAQMD	Y		100 gal/yr	BAAQMD	P/E	Records
Solvent	Permit			in any 12 consecutive	Permit		
Usage	Condition			months	Condition		
	6062 part 2				6062 part 5		

Table VII-E S-51, Wipe Cleaning, Facility-Wide

	Emission		Future		Monitoring	Monitoring	
	Limit	FE	Effective		Requirement	Frequency	Monitoring
Pollutant	Citation	Y/N	Date	<b>Emission Limit</b>	Citation	(P/C/N)	Type
VOC	BAAQMD	Y		Trichloroethylene	8-16-501	P/E	Records
	8-16-304			usage $\leq$ 3.2 gallons			
				per day			
1,1,1-	BAAQMD	N		55 gallons	BAAQMD	P/E	Records
trichloroethane	Permit			in any 12 consecutive	Permit		
	Condition			months	Condition		
	6062 part 1				6062 part 3		

## VII. Applicable Emission Limits & Compliance Monitoring Requirements (continued)

### Table VII-F S-52, Abrasive Blasting Facility S-53, Hopper and Cleaners S-54, Conveyor System

	Emission		Future		Monitoring	Monitoring	
	Limit	FE	Effective		Requirement	Frequency	Monitoring
Pollutant	Citation	Y/N	Date	Emission Limit	Citation	(P/C/N)	Type
TSP	BAAQMD	Y		Ringelmann No. less	BAAQMD	С	Differential
	Regulation			than 1 for more than 3	Permit		Pressure
	6-301			minutes	Condition 7512,		Failure
	And				part 4		Warning
	BAAQMD						System
	Permit						
	Condition						
	7512 part 1						
	BAAQMD	Y		No emissions from		N	
	Regulation			source > 0.15 grains			
	6-310			per dscf of gas volume			
	BAAQMD	Y		No emissions from		N	
	Regulation			source > rate (lb/hour)			
	6-311						
	SIP 6-301	Y		Ringelmann No. 1		C	Differential
							Pressure
							Failure
							Warning
							System
	BAAQMD	Y		Particulate loading		N	
	Permit			< 0.002 grain/dscf			
	Condition						
	7512 part 1						
Abrasive	BAAQMD	Y		1,700 tons/yr	BAAQMD	P/E	Records
Usage	Permit			and	Permit		
	Condition			13.1 tons/day	Condition 7512		
	7512 parts				part 6		
	2 and 3						

ID: WNL

#### VIII. TEST METHODS

The test methods associated with the emission limit of a District regulation are generally found in Section 600 of the regulation. The following table indicates only the test methods associated with the emission limits referenced in Section VII - Applicable Emission Limits & Compliance Monitoring Requirements, of this permit

Table VIII

Applicable		
Requirement	<b>Description of Requirement</b>	Acceptable Test Methods
BAAQMD	Ringelmann No. 1 Limitation	Manual of Procedures, Volume 1, Evaluation of Visible
Regulation 6-301		Emissions
BAAQMD	Tube Cleaning	Manual of Procedures, Volume 1, Evaluation of Visible
Regulation 6-304		Emissions
BAAQMD	Particulate Weight Limitation	Manual of Procedures, Volume IV, ST-15, Particulates
Regulation 6-310		Sampling
SIP Regulation	Ringelmann No. 1 Limitation	Manual of Procedures, Volume 1, Evaluation of Visible
6-301		Emissions
BAAQMD	VOC Limits	Manual of Procedures, Volume III, Method 21,
Regulation 8-3-302		Determination of Compliance of Volatile Organic
		Compounds for Water Reducible Coatings or Manual of
		Procedures, Volume III, Method 22, Determination of
		Compliance of Volatile Organic Compounds for Solvent
		Based Coatings
BAAQMD	VOC Limits	Manual of Procedures, Volume III, Method 21,
Regulation 8-3-304		Determination of Compliance of Volatile Organic
		Compounds for Water Reducible Coatings or Manual of
		Procedures, Volume III, Method 22, Determination of
		Compliance of Volatile Organic Compounds for Solvent
		Based Coatings
BAAQMD 8-5-117	Storage of Organic Vapor	District Manual of Procedures, Volume III, Method 28,
	Liquids;	Determination of Vapor Pressure of Organic Liquids from
	Exemption, Low Vapor Pressure	Storage Tanks
BAAQMD 8-8-112	Wastewater (Oil-Water)	Manual Procedures, Volume III, Lab Method 33,
	Separators; Exemption	Wastewater Analysis for Critical Organic Compounds
	Wastewater Critical Organic	
	Compound Concentration and/or	
	Temperature	

# VIII. Test Methods (continued)

Applicable					
Requirement	<b>Description of Requirement</b>	Acceptable Test Methods			
BAAQMD	VOC Limits	Manual of Procedures, Volume III, Method 21,			
Regulation		Determination of Compliance of Volatile Organic			
8-19-302		Compounds for Water Reducible Coatings or			
		Manual of Procedures, Volume III, Method 22,			
		Determination of Compliance of Volatile Organic			
		Compounds for Solvent Based Coatings			
		Manual of Procedures, Volume IV, ST-7 or EPA Method			
		25 or 25A, Determination of Emissions of Volatile Organic			
		compounds			
		If EPA Method 25 or 25A is used, control device			
		equivalency (if applicable) is determined as prescribed in			
		55 FR 26865			
BAAQMD	VOC Limits	Manual of Procedures, Volume III, Method 21,			
Regulation		Determination of Compliance of Volatile Organic			
8-19-312		Compounds for Water Reducible Coatings or			
		Manual of Procedures, Volume III, Method 22,			
		Determination of Compliance of Volatile Organic			
		Compounds for Solvent Based Coatings			
		Manual of Procedures, Volume IV, ST-7 or EPA Method			
		25 or 25A, Determination of Emissions of Volatile Organic			
		Compounds			
		If EPA Method 25 or 25A is used, control device			
		equivalency (if applicable) is determined as prescribed in			
		55 FR 26865			
BAAQMD	VOC Limits	Manual of Procedures, Volume III, Method 21,			
Regulation		Determination of Compliance of Volatile Organic			
8-23-301		Compounds for Water Reducible Coatings or			
		Manual of Procedures, Volume III, Method 22,			
		Determination of Compliance of Volatile Organic			
		Compounds for Solvent Based Coatings			

Facility Name: PG&E, Potrero Power Plant
Permit for Facility #: A0026
Expiration Date: September 14, 2003
ID: WNL

# VIII. Test Methods (continued)

Applicable					
Requirement	<b>Description of Requirement</b>	Acceptable Test Methods			
BAAQMD	VOC Limit	Manual of Procedures, Volume III, Method 21,			
Regulation		Determination of Compliance of Volatile Organic			
8-31-302		Compounds for Water Reducible Coatings or			
		Manual of Procedures, Volume III, Method 22,			
		Determination of Compliance of Volatile Organic			
		Compounds for Solvent Based Coatings			
		Manual of Procedures, Volume III, Method 31,			
		Determination of Precursor Organic Compounds in Paint			
		Strippers for Aerospace Assembly and Component Coating			
		Operations			
BAAQMD	Flexible Coatings	Manual of Procedures, Volume III, Method 21,			
Regulation		Determination of Compliance of Volatile Organic			
8-31-306		Compounds for Water Reducible Coatings or			
		Manual of Procedures, Volume III, Method 22,			
		Determination of Compliance of Volatile Organic			
		Compounds for Solvent Based Coatings			
BAAQMD	VOC Limits	Manual of Procedures, Volume III, Method 21,			
Regulation		Determination of Compliance of Volatile Organic			
8-31-309		Compounds for Water Reducible Coatings or			
		Manual of Procedures, Volume III, Method 22,			
		Determination of Compliance of Volatile Organic			
		Compounds for Solvent Based Coatings			
BAAQMD	General Emission Limits	Manual of Procedures, Volume IV, ST-19 A or B,			
9-1-302	Sampling and Analysis of Gas Stre				
		Procedures, Volume III, Method 10, Sulfur Content of			
		Fuels			
BAAQMD	Fuel Burning (Liquid and Solid	Manual of Procedures, Volume III, Method 10,			
9-1-304	Fuels)	Determination of Sulfur in Fuel Oils.			
BAAQMD	NOx Emissions for Units Rated	District Manual of Procedures, Volume IV, ST-13A,			
9-3-301	at 1.75 billion BTU Per Hour or More	Determination of Nitrogen Oxides; ST-14, Determination			
	1,1010	of Oxygen; ST-5, Determination of Carbon Dioxide, ST-6			

Facility Name: PG&E, Potrero Power Plant
Permit for Facility #: A0026
Expiration Date: September 14, 2003
ID: WNL

# VIII. Test Methods (continued)

Applicable					
Requirement	<b>Description of Requirement</b>	Acceptable Test Methods			
BAAQMD 9-9-302	NOx Emissions from Stationary Gas Turbines	District Manual of Procedures, Volume IV, ST-13A or B, Determination of Nitrogen Oxides; ST-14, Determination of Oxygen			
BAAQMD 9-11-302	NOx Emissions from Utility Electric Power Generating Boilers, Interim Compliance NOx Emission Limits for Boilers with a Rated Heat Input Capacity Greater Than or Equal to 1.75	District Manual of Procedures, Volume IV, ST-13A, Determination of Nitrogen Oxides; ST-14, Determination of Oxygen; ST-5, Determination of Carbon Dioxide, ST-6			
BAAQMD 9-11-302.1.1	billion BTU/hour  NOx Emissions from Utility Electric Power Generating Boilers, Gaseous Fuel	District Manual of Procedures, Volume IV, ST-13A, Determination of Nitrogen Oxides; ST-14, Determination of Oxygen; ST-5, Determination of Carbon Dioxide, ST-6			
BAAQMD 9-11-302.1.2	NOx Emissions from Utility Electric Power Generating Boilers, Non-Gaseous Fuel	District Manual of Procedures, Volume IV, ST-13A, Determination of Nitrogen Oxides; ST-14, Determination of Oxygen; ST-5, Determination of Carbon Dioxide, ST-6			
BAAQMD 9-11-302.1.3	NOx Emissions from Utility Electric Power Generating Boilers, Gaseous Fuel and Non-Gaseous Fuel	District Manual of Procedures, Volume IV, ST-13A, Determination of Nitrogen Oxides; ST-14, Determination of Oxygen; ST-5, Determination of Carbon Dioxide			
BAAQMD 9-11-308	System-wide NOx Emission Rate Limit	District Manual of Procedures, Volume IV, ST-13A, Determination of Nitrogen Oxides; ST-14, Determination of Oxygen; ST-5, Determination of Carbon Dioxide			
BAAQMD 9-11-309	Advanced Technology Alternative Emission Control Plan	District Manual of Procedures, Volume IV, ST-13A, Determination of Nitrogen Oxides; ST-14, Determination of Oxygen; ST-5, Determination of Carbon Dioxide			
BAAQMD 9-11-309.1	System-wide NOx Emission Rate Limits	District Manual of Procedures, Volume IV, ST-13A, Determination of Nitrogen Oxides; ST-14, Determination of Oxygen; ST-5, Determination of Carbon Dioxide			
BAAQMD CO Emission Limits During 9-11-310.1 Steady-State Compliance Tests		District Manual of Procedures, Volume IV, ST-6, Determination of Carbon Monoxide; ST-14, Determination of Oxygen; ST-5, Determination of Carbon Dioxide, ST-6,			

Facility Name: PG&E, Potrero Power Plant Permit for Facility #: A0026 Expiration Date: September 14, 2003

ID: WNL

# VIII. Test Methods (continued)

Applicable			
Requirement	<b>Description of Requirement</b>	Acceptable Test Methods	
BAAQMD 9-11-310.2	CO Emission Limits During Normal Operations	District Manual of Procedures, Volume IV, ST-6,	
711 510.2		Determination of Carbon Monoxide; ST-14,	
		Determination of Oxygen; ST-5, Determination of Carbon	
		Dioxide	
BAAQMD		District Manual of Procedures, Volume IV, ST-1B, EPA	
9-11-311		Method 350.3 and Determination of Ammonia, or	
		alternative method approved by the APCO	
BAAQMD 11-1-301	Hazardous Pollutants, Lead, Daily Emissions	District Manual of Procedures, Volume IV, ST-9,	
		Determination of Daily Emission Limits	

Facility Name: PG&E, Potrero Power Plant Permit for Facility #: A0026

Expiration Date: December 31, 2002

ID: WNL

## IX. TITLE IV ACID RAIN PERMIT

## Effective January 1, 1998 through December 31, 2002

## **ISSUED TO:**

Pacific Gas and Electric Company Potrero Power Plant 1201 Illinois Street San Francisco, CA 94107

## PLANT SITE LOCATION:

1201 Illinois Street San Francisco, CA 94107

## **ISSUED BY:**

Ellen Garvey, Executive Officer/
Air Pollution Control Officer

**Type of Facility:** Electric Generation

Primary SIC: 4911

**Product:** Electricity

## **DESIGNATED REPRESENTATIVE**

Name: E. James Macias

Title: Senior Vice President and General Manager

Generation, Transmission, and Supply

Phone: (415) 973-1441

## **FACILITY CONTACT PERSON:**

Name: Mike Lyons

**Title: Production Supervisor** 

Phone: (415) 695-2607

Permit for Facility #: A0026 Expiration Date: December 31, 2002

ID: WNL

## IX. Acid Rain Permit (continued)

### **ACID RAIN PERMIT CONTENTS**

- 1) Statement of Basis
- 2) SO<sub>2</sub> allowance allocated under this permit and NOx requirements for each affected unit.
- 3) Comments, notes and justifications regarding permit decisions and changes made to the permit application forms during the review process, and any additional requirements of conditions.
- 4) The permit application submitted for this source. The owners and operators of the source must comply with the standard requirements and special provisions set forth in he application.

## 1) STATEMENT OF BASIS

Statutory and regulatory Authorities: In accordance with District Regulation 2, Rule 7 and Titles IV and V of the Clean Air Act, the Bay Area Air Quality Management District issues this permit pursuant to District Rule Regulation 2, Rule 7.

## 2) SO2 ALLOWANCE ALLOCATIONS

	Year	1998	1999	2000	2001	2002
	SO <sub>2</sub> allowances	NA	NA	321*	321*	321*
	under Tables 2, 3,					
	or 4 of 40 CFR Part					
	73					
BOILER 3-1	NOx Limit	This unit is not subject to the NOx requirements from 40				
BAAQMD S-1		CFR Part 76 as this unit is not capable of firing on coal.				

<sup>\*</sup> The number of allowances allocated to Phase II affected units by U.S. EPA may change in a 1998 revision to 40 CFR part 73 Tables 2, 3, and 4. In addition, the number of allowances actually held by an affected source in a unit account may differ from the number allocated by USEPA. Neither of the aforementioned conditions necessitate a revision to the unit SO<sub>2</sub> allowance allocations identified in this permit.

Permit for Facility #: A0026 Expiration Date: December 31, 2002

ID: WNL

# IX. Acid Rain Permit (continued)

## 3) COMMENTS, NOTES AND JUSTIFICATIONS

None

## 4) PERMIT APPLICATION

Attached

Permit for Facility #: A0026 Expiration Date: September 14, 2003

ID: WNL

## X. GLOSSARY

#### **AB 2588**

California Assembly Bill 2588 (Air Toxic "Hot Spots" Program)

## **APCO**

Air Pollution Control Officer

#### **ASTM**

American Society for Testing and Materials

## **BAAQMD**

Bay Area Air Quality Management District

#### **BACT**

Best Available Control Technology

#### **CAA**

The federal Clean Air Act

## **CAAQS**

California Ambient Air Quality Standards

## **CEMS**

Continuous Emission Monitoring System

#### CEQA

California Environmental Quality Act

#### **CFR**

The Code of Federal Regulations. 40 CFR contains the implementing regulations for federal environmental statutes such as the Clean Air Act. Parts 50-99 of 40 CFR contain the requirements for air pollution programs.

## $\mathbf{CO}$

Carbon Monoxide

### **Cumulative Increase**

The sum of permitted emissions from each new or modified source since a specified date. Used to determine whether threshold-based requirements are triggered.

Permit for Facility #: A0026 Expiration Date: September 14, 2003

ID: WNL

## X. Glossary (continued)

## **District**

The Bay Area Air Quality Management District

#### **EPA**

The federal Environmental Protection Agency

## Federally Enforceable, FE

All limitations and conditions which are enforceable by the Administrator of the EPA including those requirements developed pursuant to 40 CFR Part 51, subpart I (NSR), Part 52.21 (PSD), Part 60, (NSPS), Part 61, (NESHAPS), Part 63 (HAP), and Part 72 (Permits Regulation, Acid Rain), and also including limitations and conditions contained in operating permits issued under an EPA-approved program that has been incorporated into the SIP.

#### FR

Federal Register

#### **HAP**

Hazardous Air Pollutant. Any pollutant listed pursuant to Section 112(b) of the Act. Also refers to the program mandated by Title I, Section 112, of the Act and implemented by both 40 CFR Part 63, and District Regulation 2, Rule 5.

## **Major Facility**

A facility with potential emissions of regulated air pollutants greater than or equal to 100 tons per year, greater than or equal to 10 tons per year of any single hazardous air pollutant, and/or greater than or equal to 25 tons per year of any combination of hazardous air pollutants, or such lesser quantity as determined by the EPA administrator.

#### **MFR**

Major Facility Review. The District's term for the federal operating permit program mandated by Title V of the Act and implemented by District Regulation 2, Rule 6.

#### **MOP**

The District's Manual of Procedures

#### N/A

Not applicable

#### **NAAOS**

National Ambient Air Quality Standards

### **NESHAPS**

National Emission Standards for Hazardous Air Pollutants (Contained in 40 CFR Part 61)

Permit for Facility #: A0026 Expiration Date: September 14, 2003

ID: WNL

## X. Glossary (continued)

### **NMHC**

Non-methane Hydrocarbons

#### **NO**x

Oxides of nitrogen

#### **NSPS**

Standards of Performance for New Stationary Sources. Federal standards for emissions from new stationary sources. Mandated by Title I, Section 111 of the Act, and implemented by both 40 CFR Part 60 and District Regulation 10.

#### **NSR**

New Source Review. A federal program for preconstruction review and permitting of new and modified sources of air pollutants for which the District is classified "non-attainment". Mandated by Title I of the Clean Air Act and implemented by 40 CFR Parts 51 and 52 as well as District Regulation 2, Rule 2. (Note: There are additional NSR requirements mandated by the California Clean Air Act.)

## **Offset Requirement**

A New Source Review requirement to provide federally enforceable emission offsets at a specified ratio for the emissions from a new or modified source and any pre-existing cumulative increase minus any on-site contemporaneous emission reduction credits. Applies to emissions of POC, NO<sub>X</sub>, PM10, and SO<sub>2</sub>.

#### PG&E

Pacific Gas & Electric Company

#### **Phase II Acid Rain Facility**

A facility that generates electricity for sale through fossil-fuel combustion and by virtue of certain other characteristics (defined in Regulation 2, Rule 6) is subject to Titles IV and V of the Clean Air Act.

#### **POC**

Precursor Organic Compounds

#### **PM**

Total Particulate Matter

#### PM10

Particulate matter with aerodynamic equivalent diameter of less than or equal to 10 microns

Permit for Facility #: A0026 Expiration Date: September 14, 2003

ID: WNL

## X. Glossary (continued)

#### **PSD**

Prevention of Significant Deterioration. A federal program for permitting new and modified sources of air pollutants for which the District is classified "attainment" of the National Air Ambient Quality Standards. Mandated by Title I of the Act and implemented by both 40 CFR Part 52 and District Regulation 2, Rule 2.

#### SIP

State Implementation Plan. State and District programs and regulations approved by EPA and developed in order to attain the National Air Ambient Quality Standards. Mandated by Title I of the Act.

#### $SO_2$

Sulfur dioxide

#### ST

Source test

## Title V

Title V of the federal Clean Air Act. Requires a federally enforceable operating permit program for major and certain other facilities.

## **TSP**

**Total Suspended Particulate** 

## **VOC**

Volatile Organic Compounds

## **Units of Measure:**

BTU **British Thermal Unit** dscf = dry standard cubic feet gallon gal hp horsepower hr hour = lh = pound maximum max =

min = minute MM = million

ppmv = parts per million, by volume psia = pounds per square inch, absolute

Facility Name: PG&E, Potrero Power Plant Permit for Facility #: A0026

Expiration Date: September 14, 2003
ID: WNL

## XI. APPENDIX A - APPLICABLE STATE IMPLEMENTATION PLAN

See Attachments